TYPICAL FASTENING SCHEDULE			
CONNECTION ID	CONNECTION TYPE	FASTENING	FASTENING ORIENTATION
1	JOIST TO SILL OR GIRDER	(3) - 0.131"Ø X 3"	TOENAIL
2	SOLE PLATE TO JOIST OR BLOCKING	0.148"Ø X 3¼" NAILS @ 12" OC NAILS	FACE NAIL
3	TOP PLATE TO STUD	(3) - 0.131"Ø X 3" NAILS	END NAIL
4	STUD TO SOLE PLATE - OPTION 1	(2) - 16d COMMON (3) - 0.131"Ø X 3" NAILS	END NAIL
5	STUD TO SOLE PLATE - OPTION 2	(4) 0.131"Ø X 3" NAILS	TOENAIL
6	DOUBLE/MULTIPLE STUDS	REFERENCE DETAIL 6A/S4.1	FACE NAIL
7	DOUBLE TOP PLATES	0.131"Ø X 3" NAILS @ 12" OC	FACE NAIL
8	DOUBLE TOP PLATE SPLICE	REFERENCE DETAIL 3A / S4.1	FACE NAIL
9	BLOCKING BETWEEN JOISTS/RAFTERS TO TOP PLATE	(3) - 0.131"Ø X 3" NAILS	TOENAIL
10	RIM JOIST TO TOP PLATE	0.131"Ø X 3" NAILS @ 6" OC	TOENAIL
11	CEILING JOIST TO TOP PLATE	(5) - 0.131"Ø X 3" NAILS	TOENAIL
12	CEILING JOIST LAP OVER PARTITIONS	(4) - 0.131"Ø X 3" NAILS	FACE NAIL
13	CEILING JOIST TO PARALLEL RAFTERS	(4) - 0.131"Ø X 3" NAILS	FACE NAIL
14	RAFTER TO TOP PLATE	(3) - 0.131"Ø X 3" NAILS	TOENAIL
15	BUILT-UP CORNER STUDS	0.131"Ø X 3" NAILS @ 16" OC	FACE NAIL
16	BUILT-UP BEAMS	REFERENCE DETAIL 2A / S4.0	FACE NAIL
17	COLLAR TIE TO RAFTER	(4) - 0.131"Ø X 3" NAILS	FACE NAIL
18	JACK RAFTER TO HIP	(4) - 0.131"Ø X 3" NAILS	TOENAIL
19	RAFTER TO RIDGE BOARD/BEAM	(3) - 0.131"Ø X 3" NAILS	TOENAIL
20	BLOCKING B/T STUDS	(3) - 0.131"Ø X 3" NAILS EACH SIDE	TOENAIL

NOTES: 1. THESE CONNECTIONS ARE TO BE APPLIED UNLESS NOTED OTHERWISE IN PLAN, SECTION, ELEVATION OR DETAIL VIEWS. 6D S4.0 TYPICAL WOOD FASTENING SCHEDULE

6









NOTES: 1. HOLE SIZE: THE HOLE DIAMETER SHALL NOT EXCEED 1½" OR D/10, WHICHEVER IS SMALLEST. <u>VARIANCE:</u> FOR LARGER HOLE DIAMETERS' OR FOR HOLES OUTSIDE OF THE PERMITTED ZONES, WRITTEN PERMISSION MUST BE OBTAINED FROM THE EOR.
<u>LIMITATIONS:</u> THE ABOVE CRITERIA ONLY APPLY TO SIMPLY-SUPPORTED, UNIFORMLY LOADED GLUE LAMINATED BEAMS. FOR BEAMS THAT ARE EITHER CONTINUOUS ACROSS MULTIPLE SPANS OR THAT ARE SUPPORTING NON-UNIFORM LOADS, WRITTEN PERMISSION MUST BE OBTAINED FROM THE EOR.





4D S4.0 TYPICAL NAILING CONFIGURATIONS









3 1/2"

1/2" STRUCTURALLY SHEATHING



2C TYPICAL LVL MULTIPLE PLY FASTENING REQUIREMENTS

S4.0

S4.0







Date 06/10/2022 L

4 1/2" 1

2-PLY BEAM 3-PLY BEAM (2) 10d NAILS (FACENAIL) AT ENDS AND LAYER (PLY) SPLICES

5 1/2" \times

0

2-PLY HEADER (H) 3-PLY HEADER (H) 32" MAX

